

**To:** Andy Skrip  
SLIBCO  
222 Mulberry St.  
Scranton PA 18501

**Date:** February 17, 2012

**From:** Highland Associates

**Project:** SLIBCO/MAXIMUS

**Project No.:** 2012-031

**Addendum:** #3

*A d d e n d u m*

---

This Addendum shall be made part of the Bid Document Package, dated February 10th, 2012. Revisions to the original drawings, specifications and narratives in this Addendum shall supersede the February 10th package.

**DRAWING REVISIONS:**

**Item 1: Drawing SP-1 Specifications, General Notes and Door Hardware Sets**

1. Clarification – Doors listed as Exist – 1 and Exist – 2 are on egress doors on each side of column line C
2. Telephone Room door hardware on 1<sup>st</sup> floor shall receive hardware set 2.
3. Exterior vestibule door shall receive a card reader “by others”
4. General note 27. Fire extinguisher cabinets are not required. Fire Extinguishers indicated on A-1 shall be type ABC 10 lb.

**General Comments**

1. No power is required for future RTU’s

cc: Prospective Bidders, M. Wolf, L.Norella, W:\\_2012\11-031\SLIBCO/MAXIMUS\Addendum \Addendum # 003 2/17/12.doc